



Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

### **TORREXX Electric Vaporizer**

**Models: TX25, TX50, TX100, TX160, TX240, TX320 & TX480 - TX2560**  
**XP / 1 / D / T3C Ta = 40°C**

Equipment Ratings:

### **Models: TX25, TX50, TX100, TX160, TX240 & TX320**

Model designations indicate rated vaporizing capacity in Kg/Hr. The vaporizers are available as either explosionproof for Class I, Division 1, Group D hazardous locations Temperature Class T3C.

### **Models: TX480 - TX2560**

Models TX480 thru TX2560 are assembled by combining the outputs of the TX240 and TX320. The vaporizers are available as either explosionproof for Class I, Division 1, Group D hazardous locations Temperature Class T3C.

FM Approved for:

Algas-SDI  
Seattle, WA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
CSA-C22.2 No. 0.5	1982
CSA-C22.2 No. 30	1986
CSA-C22.2 No. 94	1991
EN 60079-0	2006
EN 60079-1	2004

Original Project ID: 3026276


Canadian Project ID: 3028109

Approval Granted: *March 29, 2007*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
 Robert L. Martell, Jr.  
 Assistant Vice President

*March 29, 2007*  
 Date



**Offered By:**

Power Equipment Company  
2011 Williamsburg Road  
Richmond, Virginia 23231

T: 804-236-3800

F: 804-236-3882

[www.peconet.com](http://www.peconet.com)

[sales@peconet.com](mailto:sales@peconet.com)